WILSON IHRIG
ACOUSTICS, NOISE & VIBRATION

CALIFORNIA
WASHINGTON
NEW YORK

WI #16-085

MEMORANDUM

January 12, 2017

To: William Newby
From: Deborah Jue
Subject: Vibration Monitoring for Glenview Elementary – December 2016

Wilson Ihrig has been conducting vibration monitoring at 1550 Hampel and 1541 Wellington.

1550 Hampel

The monitoring equipment at 1550 Hampel has been in operation since the afternoon of October 3, 2016. For the month of December, no vibration events have been recorded that exceed the 0.300 in/sec peak particle velocity (PPV) threshold.

1541 Wellington

The monitoring equipment at 1541 Wellington started operation during the late morning of November 2, 2016. For the month of December, no vibration events have been recorded that exceed the 0.300 in/sec peak particle velocity (PPV) threshold.

6001 SHELLMOUND STREET, SUITE 400 | EMERYVILLE, CA 94608 | (510) 658-6719 | WWW.WILSONIHRIG.COM